MDS-G4000/MDS-G4000-L3 Series Quick Installation Guide

Version 1.3, August 2022

Technical Support Contact Information www.moxa.com/support



 $\ensuremath{\textcircled{}^\circ}$ 2022 Moxa Inc. All rights reserved.

P/N: 1802040000005

Package Checklist

Moxa's MDS-G4000/MDS-G4000-L3 Series industrial modular DIN-rail switch is shipped with the following items. If any of these items are missing or damaged, please contact your customer service representative for assistance.


- 1 MDS-G4000 or MDS-G4000-L3 Series switch
- RJ45-to-RS-232 9-pin female console cable
- 2 protective caps for unused ports
- Pre-installed DIN-rail kit
 - MDS-G4012 and MDS-G4012-L3: x 1
 - MDS-G4020 and MDS-G4020-L3: x 2
 - MDS-G4028 and MDS-G4028-L3: x 2
 - Quick installation guide (printed)
- Substance Disclosure Table
- Product Certificate of Quality Inspection (Simplified Chinese)
- Product Notices (Simplified Chinese)
- Warranty card

NOTE You can find information and software downloads on the relevant product pages located on Moxa's website: www.moxa.com

Default Settings

- IP address: 192.168.127.253
- Subnet Mask: 255.255.255.0
- Username: admin
- Password: moxa

Panel Layouts





- System status LEDs (from left to right, top to bottom) STATE, FAULT, MASTER/HEAD, COUPLER/TAIL, and SYNC LED indicators
- 2. USB port (Reserved for future use)

- 3. Module status
- 4. Switch and Control module slot 1 (Embedded)
- 5. Ethernet module slot 2
- 6. Ethernet module slot 3
- 7. Ethernet module slot 4 (For MDS-G4020/28, MDS-G4020/28-L3)
- 8. Ethernet module slot 5 (For MDS-G4020/28, MDS-G4020/28-L3)
- 9. External power input status from EPS
- 10. Ethernet module slot 6 (For MDS-G4028, MDS-G4028-L3)
- 11. Ethernet module slot 7 (For MDS-G4028, MDS-G4028-L3)
- 12. External power supply input for PoE
- 13. Redundant power module slot 1
- 14. Redundant power module slot 2
- 15. RS232 console port with RJ45 interface
- 16. Reset button (Pin hole 0.9 mm)
- 17. Relay output and Digital Input port
- 18. Relay output
- 19. Powerinput
- 20. Grounding screw


Dimensions

MDS-G4012 and MDS-G4012-L3 Series












Unit: mm (inch)






Ethernet Modules (Hardware Rev. 2.0.0 and above)

NOTE Transceivers for the LM-7000H-4GSFP module are sold separately. Refer to <u>Supported SFP Modules</u> for list of supported transceivers.



Power Modules (Hardware Rev.2.1.0 and above)


NOTE The PWR-LV-P48 power module is certified for Hazardous Location use.



DIN-rail Dimensions and Instructions


NOTE The DIN rail kit is certified for Hazardous Location usage.

MDS-G4012 and MDS-G4012-L3 Series



Unit: mm (inch)

MDS-G4020/28 and MDS-G4020/28-L3 Series



- 1. Insert the upper lip of the DIN rail into the DIN-rail mounting kit.
- 2. Press the device towards the DIN rail until it snaps into place.
- 3. Pull down the two latches one by one to release the DIN-rail kit and lift up to remove the device from the DIN rail.

NOTE The DIN rail must use the TS35 (15 mm) specification.


Wall-mounting Dimensions and Instructions


(Optional: WK-112-01)

NOTE The wall-mount kit is certified for Hazardous Location usage.

Mounting the switch to a wall requires four screws. The heads of the screws should be between 6.0 to 9.0 mm in diameter, and the diameter of screw thread should be between 3.5 to 4 mm, as shown in the figure on the right. Use the switch with the wall-mounting kit attached as a guide to mark the correct locations of the eight screws.








Rack-mounting Dimensions and Instructions


(Optional: RK-3U-01)

The rack mount kit is designed for two MDS-G4028 or MDS-G4028-L3 products.




- 1. Assemble the right and left part of the kit (indicated with No. 1 in the diagram) with four screws each.
- 2. Assemble the part of the rack kit (indicated with No. 2 in the diagram) with eight screws in order to combine two MDS-G4028 or MDS-G4028-L3 products.

Rack Mount Top View



Rack Mount Front View



Rack Mount Rear View



Matters That Require Attention

- 1. Elevated Operating Temperature: If installed in a closed or multi-unit rack assembly, the operating ambient temperature of the rack environment may be greater than room temperature. Therefore, consideration should be given to installing the equipment in an environment compatible with the maximum ambient temperature (Tma) specified by the manufacturer.
- **NOTE** In order to ensure reliable operations, please make sure the operating temperature of the environment does not exceed the spec. When mounting a rack-mounted switch with other operating units in a cabinet without forced ventilation, it is recommended that 1U of space is reserved between each rack-mounted switch and/or device.
- 2. Required Air Flow: Installation of the equipment in a rack should be such that the amount of air flow required for safe operation of the equipment is not compromised.

NOTE The optimal keep-out zone is 50 mm for the top, bottom, left, and right side of the device.

- **3. Mechanical Loading:** Mounting of the equipment in the rack should be such that a hazardous condition is not achieved due to uneven mechanical loading.
- 4. Circuit Overloading: Consideration should be given to the connection of the equipment to the supply circuit and the effect that overloading of the circuits might have on overcurrent protection and supply wiring. Appropriate consideration of equipment nameplate ratings should be used when addressing this concern.
- 5. **Reliable Grounding:** Reliable grounding of rack-mounted equipment should be maintained. Particular attention should be given to supply connections other than direct connections to the branch circuit (e.g. use of power strips).



Be sure to disconnect the power cord before installing and/or wiring your Ethernet Switch. Calculate the maximum possible current in each power wire and common wire. Observe all electrical codes dictating the maximum current allowable for each wire size. If the current goes above the maximum ratings, the wiring could overheat, which can cause serious damage to your equipment.

Connecting the Power Inputs

The MDS-G4000 and MDS-G4000-L3 Series support 4 types of power supply:

- PWR-HV-P48: one 110/220 VAC/VDC (90 to 264 VAC, 88 to 300 VDC), one 48 VDC PoE power input for PoE+ ports.
- PWR-LV-P48: one 24/48 VDC (18 to 72 VDC), one 48 VDC PoE power input for PoE+ ports.
- **NOTE** The required power module depends on the choice of LM-7000H module. Refer to the following power/module combination requirements.
 - LM-7000H non-PoE modules: Any power module
 - LM-7000H PoE modules: PWR-HV-P48, PWR-LV-P48 only

NOTE The PWR-LV-P48 power module is certified for Hazardous Location use.

- PWR-HV-NP: one 110/220 VAC/VDC (90 to 264 VAC, 88 to 300 VDC) power input.
- PWR-LV-NP: one 24/48 VDC (18 to 72 VDC) power input.

For the PWR-HV-P48, the 110/220 VAC/VDC power supplies provide power to the switch. Separate 48 VDC power supplies are required to provide power to all PoE+ ports (50 to 57 VDC is recommended for IEEE 802.3at devices. The max. PoE output from an external power supply is 720 W when the operating temperature is under 60°C; 360 W when the operating temperature is under 75°C.).

For the PWR-LV-P48 models, the 24/48 VDC power supplies provide power to the switch. Separate 48 VDC power supplies are required to provide power to all PoE+ ports (50 to 57 VDC is recommended for IEEE 802.3at devices. The max. PoE output from an external power supply is 720 W when the operating temperature is under 60°C; 360 W when the operating temperature is under 75°C.).



ATTENTION

For Hazardous Location Use

The PoE capacity of the PWR-LV-P48 is only certified for use in hazardous locations up to a maximum power budget of 369.6 W and a maximum output of up to 15.4 W per port.

For the PWR-HV-NP, the 110/220 VAC/VDC power supplies provide power to the switch.


For the PWR-LV-NP, the 24/48 VDC power supplies provide power to the switch.

Power Terminal Blocks

The connection for power input and PoE external power supply is on the power modules.




PWR-HV-P48/PWR-HV-NP



- 1. Insert the neutral/line (L/N/Ground) AC wires into the terminals.
- 2. Insert the terminal block connector into the terminal block receptor.

PWR-LV-P48/PWR-LV-NP



- 1. Remove 8 to 9 mm of the DC wires' protective cover.
- 2. Use a tool to push the spring mechanism inwards to open it.
- 3. Insert the negative/positive (-/+) DC wires into the terminals.
- 4. Release the spring mechanism.
- 5. Insert the terminal block connector prongs into the terminal block receptor.

PoE Power Terminal Blocks

- 1. Remove 8 to 9 mm of the DC wires' protective cover.
- 2. Use a tool to push the spring mechanism inwards to open it.
- 3. Insert the negative/positive (-/+) DC wires into the terminals.
- 4. Release the spring mechanism.
- 5. Insert the terminal block connector prongs into the terminal block receptor.
- **NOTE** In order to have higher levels of protection against surge, it is suggested to install a surge protector in front of the power input of the PoE powered device so that it is suitable for use in IEC 61850 conditions.
- **NOTE** When wiring the power input, we suggest using the cable type -AWG (American Wire Gauge) 16-20 (1.31-0.519 mm²) and the corresponding pin type cable terminals. The rated temperature of wiring should be at least 105°C.
- **NOTE** When wiring the PoE power input, we suggest using the cable type AWG (American Wire Gauge) 16 (1.31 mm²) and the corresponding pin type cable terminals. The rated temperature of wiring should be at least 105°C.
- **NOTE** When two power units are installed on the switch, both power units will be activated simultaneously, which will enable power redundancy.
- **NOTE** The reverse power input connection will not activate the device or PoE input. In addition, the PoE will only activate when the external power supply is installed on the same power unit.

Wiring the Relay Contact

Each power module has one relay output that can provide two types of relay output. Refer to the table below for detailed information.

The relay contact is used to detect user-configured events. Two wires are attached to the relay pins with normally close and normally open options.

- 1. Remove 8 to 9 mm of the DC wires' protective cover.
- 2. Use a tool to push the spring mechanism inwards to open it.
- 3. Insert the wires into the terminals.
- 4. Release the spring mechanism.
- 5. Insert the terminal block connector prongs into the terminal block receptor.

FAULT:

The relay contact of the 3-pin terminal block connector is used to detect user-configured events. The module provides normally open and normally closed circuits depending on what the user chooses. For pin definitions refer to the table below.

| Relay Connection | Power Off | Boot up Ready | Event Trigger |
|-------------------------|----------------|----------------|----------------|
| NO and COM | Closed Circuit | Open Circuit | Closed Circuit |
| NC and COM | Open Circuit | Closed Circuit | Open Circuit |

NOTE When wiring the relay contact, we suggest using the cable type - AWG (American Wire Gauge) 16-20 (1.31-0.519 mm²) and the corresponding pin type cable terminals. The rated tem perature of wiring should be at least 105°C.

Digital Input/Output

Digital Output

1 relay output with current carrying capacity of 2 A @ 30 VDC

NOTE For Hazardous Location certified models, the current carrying capacity is 1 A @ 30 VDC.

Digital Input

1 digital output with the same ground, but electrically isolated from the electronics

- +13 to +30 V for state 1
- -30 to +1 V for state 0
- Max. input current: 8 mA

Wiring the Digital Input/Output

- **NOTE** When wiring the digital input, we suggest using the cable type -AWG (American Wire Gauge) 16-24 (1.31-0.205 mm²) and the corresponding pin type cable terminals. The rated temperature of wiring should be at least 105°C.
 - 1. Remove 8 to 9 mm of the DC wires' protective cover.
 - 2. Use a tool to push the spring mechanism inwards to open it.
 - 3. Insert the wires into the terminals.
 - 4. Release the spring mechanism.
 - 5. Insert the terminal block connector prongs into the terminal block receptor.

Installing and Removing the Ethernet Modules

The Ethernet modules are hot-swappable for the same module type. You have the option to mount or remove the Ethernet module while the device is operating.

NOTE When performing a cold start, you cannot remove and insert a module before booting up as it will cause the module to initially fail.

- **NOTE** The default module is 4GTX, if it is the first time you are mounting a 4TX, PoE, or SFP module, please reboot the switch after inserting it. The hot-swappable function, as defined above, will only work after the device is rebooted for the first time.
- **NOTE** If a different model type module is changed on the same slot, it is recommended to reconfigure the settings or reset the device to default settings after rebooting the switch.

To install an Ethernet module:

- 1. Insert the Ethernet module straight into the slot.
- 2. Fasten the module to the device by tightening the 2 screws. The tightening torque is 3.5 kgf-cm (0.35 Nm).

To remove an Ethernet module:

- 1. Loosen the 2 screws of the module.
- 2. Pull the module out of the slot.
- 3. Insert the dummy module into the slot in order to have better protection against dust and EMI.
- 4. Fasten the dummy module using 2 screws. The tightening torque is 4 kgf-cm (0.4 Nm).

Installing and Removing the Power Modules

The power supply units are hot-swappable when both power modules are installed. You have the option to mount or remove the power supply units while the device is operating.

To install a power module:

- 1. Insert the power unit straight into the slot
- Fasten the unit to the device by tightening the 2 screws. The tightening torque is 3.5 kgf-cm (0.35 Nm)

To remove a power module:

- 1. Loosen the 2 screws of the module
- 2. Pull the module out of the slot
- 3. Insert the dummy module in to the slot in order to have better protection against dust and EMI.
- 4. Fasten the dummy module using 2 screws. The tightening torque is 4 kgf-cm (0.4 Nm)

NOTE If one of the modules is removed from the device, it is advisable to insert a dummy module in order to provide better protection against dust and EMI.

Grounding the Moxa Industrial DIN-rail Switch

Grounding and wire routing help limit the effects of noise due to electromagnetic interference (EMI). Run the ground connection from the ground screw to the grounding surface prior to connecting devices. **NOTE** Using a shielded cable achieves better electromagnetic resistance.

NOTE When grounding, we suggest using the cable type - AWG (American Wire Gauge) 16 (1.31 mm²).

RS-232 with RJ45 Interface Console Connection

The switch has an RS-232 serial console with an RJ45 interface. Use a Moxa 9-pin female console cable to connect to your PC's COM port (or via USB-to-Serial converters or hubs). You can then use a console terminal program, such as Moxa's PComm Terminal Emulator, to access the console configuration utility of the switch.

RS-232 Setup:

- Baud rate: 115,200
- Data Bits: 8
- Parity: None
- Stop Bits: 1
- Terminal Type: VT100

USB Connection

The USB connection is reserved for functions that may be required in the future.



| Pin | Description |
|-----|--------------|
| 1 | VCC (+5V) |
| 2 | D- (Data-) |
| 3 | D+ (Data+) |
| 4 | GND (Ground) |

The Reset Button (Diameter 0.9 mm)

The reset button can perform two functions. One is to reset the switch to factory default settings and the other is to reboot the switch if the button has been depressed and release immediately.

Reset to Factory Default Settings

Depress the Reset button for five seconds to load the factory default settings. Use a pointed object, such as a straightened paper clip or needle (the diameter must not exceed 0.9 mm), to depress the Reset button. When you do so, the STATE LED will start to blink about four times per second. Continue to depress the STATE LED until it begins blinking more rapidly; this indicates that the button has been depressed for five seconds and you can release the Reset button to load factory default settings.

NOTE DO NOT power off the switch when loading default settings.

LED Indicators

The function of each LED is described in the table below.

| LED | Color | State | Description |
|-----------------|------------|-----------|---------------------------------------|
| | | Syst | em LEDs |
| | | On | Normal operation. |
| STA | Green | Blinking | 1. The system is booting up. |
| (STATE) | | Off | N/A |
| . , | Red | On | The system failed to initialize. |
| | | 0 | 1. Switch failed to initialize. |
| FI T | | On | 2. EEPROM information error. |
| FLT (FALLET) | Red | Blinking | When the switch boots up and the |
| (FAULT) | | DIITKIIIY | firm ware loads to memory. |
| | | Off | The system is operating normally. |
| | | On | When the switch is the Master/Head |
| | | UII | of Turbo Ring/Turbo Chain. |
| M/H | | | When the switch is Ring Master/Head |
| (MSTR/ | Green | Blinking | of Turbo Ring/Turbo Chain and the |
| HEAD) | Green | | Turbo Ring/Turbo Chain is broken. |
| nene) | | | When the switch is not the |
| | | Off | Master/Head of this Turbo |
| | | | Ring/Turbo Chain. |
| | | | 1. When the switch enables the |
| | | _ | coupling function to form a back-up |
| | | On | path, or |
| | | | 2. When the switch is the tail of |
| C/T | Green | | Turbo Chain. |
| (CPRL/TAIL) | 0.001 | Blinking | This is the switch that enables Turbo |
| | | | Chain, but the Turbo Chain function |
| | | | is not working. |
| | | Off | When the switch disables the |
| | | - | coupling or tail role of Turbo Chain. |
| | | On | The PTP function is enabled. |
| SYNC | Amber | Blinking | The switch receives sync packets. |
| (Reserved) | (Reserved) | Off | The PTP function is disabled. |
| · , | Green | On | The PTP function has successfully |
| | | | converged. |
| | <u> </u> | | The switch is being |
| System LED | Green/ | Dimbin - | discovered/located by the locator |
| (Except | Amber/ | Blinking | function. The system LEDs include |
| PWR) | Red | | the STA, FLT, M/H, C/T, and SYNC |
| | | | LEDs. |

SWC-4GTX

| LED | Color | State | Description |
|---------------------------------|-------|----------|---|
| | | On | Normal operation. |
| MS | Green | Blinking | This module is booting up. |
| (Module | | Off | The module is out of service. |
| State) | Red | On | The module failed to initialize. A module designed for a different model was inserted. |
| | Green | On | When the port is active and links on 1,000 Mbps. |
| Connor | | Blinking | When the port's data is being transmitted at 1,000 Mbps. |
| Copper (10/100/ 1000Mbps) | | Off | When the port is inactive or link down. |
| 100010005) | Amber | On | When the port is active and links on 10/100 Mbps. |
| | Amber | Blinking | When the port's data is being transmitted at 10/100 Mbps. |

LM-7000H-4GTX/LM-7000H-4GSFP/LM-7000H-4TX

| LED | Color | State | Description |
|-----------------------|-----------------------------|------------|--|
| | | On | Normal operation. |
| MC | Green | Blinking | This module is booting up. |
| MS (Module | | Off | The module is out of service. |
| State) | | | 1. The module failed to initialize. |
| State) | Red | On | 2. A module designed for a different |
| | | | model was inserted. |
| | | On | When the port is active and links on |
| | | OII | at 100 Mbps. |
| | Green | Blinking | When the port's data is being |
| | | | transmitted at 100 Mbps. |
| Copper | | Off | When the port is inactive or link |
| (10/100 | | | down. |
| Mbps) | | On | When the port is active and links on |
| . , | | | 10 Mbps. |
| | Amber | Blinking | When the port's data is being transmitted at 10 Mbps. |
| | | | When the port is inactive or link |
| | | Off | down. |
| | | On | When the port is active and links on |
| | | | 1,000 Mbps. |
| | Green | | When the port's data is being |
| | | Blinking | transmitted at 1,000 Mbps. |
| 6 | | Off | When the port is inactive or link |
| Copper (10/100/ | | OII | down. |
| (10/100/ 1000Mbps) | | On | When the port is active and links on |
| 1000Mbps) | | | 10/100 Mbps. |
| | Amber | Blinking | When the port's data is being |
| | Amber | Dillinking | transmitted at 10/100 Mbps. |
| | | Off | When the port is inactive or link |
| | | 011 | down. |
| | | On | When the port is active and links on |
| G | | | 1,000Mbps. |
| | Green | Blinking | When the port's data is being transmitted at 1,000 Mbps. |
| | | | When the port is inactive or link |
| SFP | | Off | down. |
| (100/1000 | (100/1000 Mbps) Amber | On | When the port is active and links on |
| Mbps) | | | 100 Mbps. |
| | | Blinking | When the port's data is being |
| | | | transmitted at 100 Mbps. |
| | | Off | When the port is inactive or link |
| | | | down. |

LM-7000H-4GPoE/LM-7000H-4PoE

| LED | Color | State | Description |
|--|-------------|----------|---|
| | | On | Normal operation. |
| | Green | Blinking | The module is booting up. |
| | | Off | This module is out of service. |
| MS (Module State) | Red | On | The module failed to initialize. A user inserted a module designed for a different model. When performing a cold start, the module was removed and inserted before initialization was complete. |
| EPS | | On | Normal operation. |
| (External Power Supply for PoE module) | Amber | | No external power supply for PoE. |
| | | On | When the port is active and links on 100 Mbps. |
| | Green | Blinking | When the port's data is being transmitted at 100 Mbps. |
| Copper (10/100 | | Off | When the port is inactive or link down. |
| Mbps) | | On | When the port is active and links on 10 Mbps. |
| | Amber | Blinking | When the port's data is being transmitted at 10 Mbps. |
| | | Off | When the port is inactive or link down. |
| | Green | On | When the port is active and links on 1,000 Mbps. |
| | | Blinking | When the port's data is being transmitted at 1,000 Mbps. |
| Copper (10/100/ | | Off | When the port is inactive or link down. |
| 1000Mbps) | | On | When the port is active and links on 10/100Mbps. |
| | Amber | Blinking | When the port's data is being transmitted at 10/100 Mbps. |
| | | Off | When the port is inactive or link down. |
| | | On | When the port is connected to IEEE 802.3at powered device (PD). |
| | Green | Off | When the power is not being supplied to a powered device (PD), or The port is not connected to an IEEE 802.3at standard PD. |
| PoE/PoE+ | A ma la a m | On | When the port is connected to IEEE 802.3af powered device (PD). |
| | Amber | Blinking | The PoE power has been shut off because of low power budget. |
| | Ded | On | Powered device (PD) detection failure. |
| | Red | Blinking | When detecting over current or short circuit on the powered Device (PD). |

PWR-HV-P48/PWR-LV-P48

| LED | Color | State | Description |
|--------------------------------|---------------|---|--|
| EPS (External Power Supply) | On | External power is being supplied to the module's EPS input. | |
| Power Supply) | Power Supply) | Off | No external power supply for PoE. |
| 214/2 | A | On | Power is being supplied to the module's power input. |
| PWR | PWR Amber | Off | Power is not being supplied to the module's power input. |

PWR-HV-NP/PWR-LV-NP

| LED | Color | State | Description |
|-------|-------|-------|--|
| 511/5 | A | On | Power is being supplied to the module's power input. |
| PWR | Amber | Off | Power is not being supplied to the module's power input. |

Specifications

| Interface | |
|-----------------------|--|
| Gigabit Ethernet | 4-ports 10/100/1000BaseT(X) |
| Console Port | RS-232 console with an RJ45 interface |
| LED Indicators | PWR, EPS, STATE, SYNC, FAULT, MSTR/HEAD, |
| | CPLR/TAIL |
| Relay Output | 2 A @ 30 VDC (for Hazardous Location certified |
| | models, the current carrying capacity is 1 A @ 30 |
| | VDC.) |
| Power Requirer | nents |
| Input Voltage | PWR-HV-P48: |
| | 110/220 VDC, 110 VAC, 60 Hz, 220 VAC, 50 Hz, |
| | PoE: 48 VDC |
| | PWR-LV-P48 (certified for Hazardous Location |
| | use): |
| | 24/48 VDC |
| | PoE: 48 VDC |
| | PWR-HV-NP: |
| | 110/220 VDC, 110 VAC, 60 Hz, 220 VAC, 50 Hz |
| a | PWR-LV-NP: 24/48 VDC |
| Operating | PWR-HV-P48: |
| Voltage | 88 to 300 VDC, 90 to 264 VAC, 47 to 63 Hz, PoE: 46 |
| | to 57 VDC |
| | PWR-LV-P48: 18 to 72 VDC (24 to 48 VDC for |
| | Hazardous Location), PoE: 46 to 57 VDC (48 VDC for |
| | Hazardous Location) |
| | |
| | 88 to 300 VDC, 90 to 264 VAC, 47 to 63 Hz |
| | PWR-LV-NP:18 to 72 VDC |

| Power When using PWR-HV-P48: Consumption 110 VDC: 12.43 W | |
|--|---------|
| | |
| (without 220 VDC: 12.87 W | |
| modules 110 VAC: 13.42 W | |
| consumption) 220 VAC: 14.08 W | |
| When using PWR-LV-P48: | |
| 24 VDC: 12.67 W | |
| 48 VDC: 13.2 W | |
| Power LM-7000H-4GTX: 3.63 W | |
| Consumption of LM-7000H-4GPoE: 3.8 W | |
| module LM-7000H-4GSFP: 4.8 W | |
| LM-7000H-4TX: 1.85 W | |
| LM-7000H-4PoE: 1.85 W | |
| Input Current When using PWR-HV-P48/PWR-HV-NP: | |
| (without 110 VDC: 0.11 A | |
| modules 220 VDC: 0.06 A | |
| consumption) 110 VAC: 0.29 A | |
| 220 VAC: 0.18 A | |
| When using PWR-LV-P48/PWR-LV-NP: | |
| 24 VDC: 0.53 A | |
| 48 VDC: 0.28 A | |
| Peak Inrush PWR-HV-P48/PWR-HV-NP : | |
| Current $110 \text{ VAC:} < 10 \text{ A} (t > 0.1 \text{ ms})$ | |
| 220 VAC: < 20 A (t > 0.1 ms) | |
| PWR-LV-P48/PWR-LV-NP: | |
| 24 VDC: < 5 A (t > 0.1 ms) | |
| 48 VDC: < 10 A (t > 0.1 ms) | |
| Maximum PoE 36 W | |
| Power Output 15.4 W certified for Hazardous Location use | |
| per Port | |
| Total PoE Power Max. 360 W (with one power supply) for total PI | C |
| Budget consumption at 48 VDC input for PoE systems | |
| Max. 360 W (with one power supply) for total PI | C |
| consumption at 53-57 VDC input for PoE+ syste | |
| Max. 720 W (with two power supplies) for total | |
| consumption at 48 VDC input for PoE systems | |
| Max. 720 W (two powers) for total PD consumpt | tion at |
| 53-57 VDC input for PoE+ systems | |
| Overload Current Present | |
| Protection | |
| Reverse Polarity Present | |
| Protection | |
| Physical Characteristics | |
| Ingress IP40 (This rating will only be achieved when the | e relav |
| Protection Rating output terminal block and all modules are instal | |
| Dimensions MDS-G4012/MDS-G4012-L3 Series: | |
| 134 x 115 x 163.25 mm | |
| | |
| MDS-G4020/ MDS-G4020-L3 Series: | |
| MDS-G4020/ MDS-G4020-L3 Series: 176 x 115 x 163.25 mm | |
| | |

| | 1 |
|-------------------|---|
| Weight | MDS-G4012/MDS-G4012-L3 Series: 2.00 kg (4.41 lb) |
| | MDS-G4020/MDS-G4020-L3 Series: 2.50 kg (5.51 lb) |
| | MDS-G4028/MDS-G4028-L3 Series: 2.84 kg (6.26 lb) |
| | LM-7000H-4GSFP: 0.3 kg (0.66 lb) |
| | LM-7000H-4GTX: 0.24 kg (0.53 lb) |
| | LM-7000H-4GPoE: 0.31 kg (0.69 lb) |
| | LM-7000H-4TX: 0.24 kg (0.53 lb) |
| | LM-7000H-4PoE: 0.31 kg (0.69 lb) |
| | PWR-HV-P48/PWR-LV-P48: 0.36 kg (0.69 lb) |
| | PWR-HV-NP/PWR-LV-NP: 0.34 kg (0.75 lb) |
| Installation | DIN-rail mounting (certified for Hazardous Location |
| | use): Pre-installed by default |
| | Wall mount (certified for Hazardous Location use): |
| | WK-112-01 (with optional kit) |
| | 19" rack mounting: RK-3U-01 (optional, only for |
| | combining two 28-port models) |
| Environmental | |
| Operating | Standard Temperature Models: |
| Temperature | -10 to 60°C (14 to 140°F) |
| | MDS-G4012, MDS-G4012-L3 |
| | MDS-G4020, MDS-G4020-L3 |
| | MDS-G4028, MDS-G4028-L3 |
| | Wide Temperature Models: |
| | -40 to 75°C (-40 to 167°F) |
| | MDS-G4012-T, MDS-G4012-L3-T |
| | MDS-G4020-T, MDS-G4020-L3-T |
| | MDS-G4028-T, MDS-G4028-L3-T |
| Storage | -40 to 85°C (-40 to 185°F) |
| Temperature | |
| Am bient Relative | 5 to 95% (non-condensing) |
| Humidity | |
| Standards and | Certifications |
| Safety | EN 62368-1, UL 62368-1, IEC 62368-1 |
| EMC | EN 55035/55032 |
| EMI | CISPR 32, FCC Part 15B Class A |
| EMS | IEC 61000-4-2 ESD: Contact: 8 kV; Air: 15 kV |
| | IEC 61000-4-3 RS: 80MHz to 1GHz: 20 V/m |
| | IEC 61000-4-4 EFT: Power: 4 kV; Signal: 4 kV |
| | IEC 61000-4-5 Surge: Power 4 kV; Signal: 4 kV |
| | IEC 61000-4-6 CS: 10V |
| | IEC 61000-4-8 PFMF |
| | IEC 61000-4-11 Voltage Dips & Interruptions |
| Note: For better | conductive radiation immunity, it is recommended to |
| | and install a surge protector at the PoE power input: |
| EPS. | |
| Rail Traffic | EN 50121-4 |
| Traffic Control | NEMA TS2 |
| Shock | IEC 60068-2-27 |
| Freefall | IEC 60068-2-31 |
| Vibration | IEC 60068-2-6 |
| Hazardous | Class I Division 2, ATEX |
| Location | |
| Power | IEC 61850-3, IEEE 1613 |
| Substation | 100 01000 0, 1000 0 |
| Sabstation | |

| Warranty | |
|-----------------|---------------------------|
| Warranty Period | 5 years |
| Details | See www.moxa.com/warranty |

Supported SFP Modules

| Module | Description |
|---------------|---|
| SFP-1FEMLC-T | SFP module with 1 100Base multi-mode, LC |
| 011 1121120 | connector for 2/4 km transmission, -40 to 85°C |
| | operating temperature |
| SFP-1FESLC-T | SFP module with 1 100Base single-mode with LC |
| SIT TIESEC I | connector for 40 km transmission, -40 to 85°C |
| | operating temperature |
| SFP-1FELLC-T | SFP module with 1 100Base single-mode with LC |
| SFP-IFELLC-I | 5 |
| | connector for 80 km transmission, -40 to 85°C |
| | operating temperature |
| SFP-1G10ALC | WDM-type (BiDi) SFP module with 1 1000BaseSFP |
| | port with LC connector for 10 km transmission; TX |
| | 1310 nm, RX 1550 nm, 0 to 60°C operating |
| | temperature |
| SFP-1G10ALC-T | WDM-type (BiDi) SFP module with 1 1000BaseSFP |
| | port with LC connector for 10 km transmission; TX |
| | 1310 nm, RX 1550 nm, -40 to 85°C operating |
| | temperature |
| SFP-1G10BLC | WDM-type (BiDi) SFP module with 1 1000BaseSFP |
| | port with LC connector for 10 km transmission; TX |
| | 1550 nm, RX 1310 nm, 0 to 60°C operating |
| | temperature |
| SFP-1G10BLC-T | WDM-type (BiDi) SFP module with 1 1000BaseSFP |
| | port with LC connector for 10 km transmission; TX |
| | 1550 nm, RX 1310 nm, -40 to 85°C operating |
| | temperature |
| SFP-1G20ALC | WDM-type (BiDi) SFP module with 1 1000BaseSFP |
| | port with LC connector for 20 km transmission; TX |
| | 1310 nm, RX 1550 nm, 0 to 60°C operating |
| | temperature |
| SFP-1G20ALC-T | WDM-type (BiDi) SFP module with 1 1000BaseSFP |
| 011 1020/201 | port with LC connector for 20 km transmission; TX |
| | 1310 nm, RX 1550 nm, -40 to 85°C operating |
| | temperature |
| SFP-1G20BLC | WDM-type (BiDi) SFP module with 1 1000BaseSFP |
| SIT IGZODEC | port with LC connector for 20 km transmission; TX |
| | 1550 nm, RX 1310 nm, 0 to 60°C operating |
| | temperature |
| SFP-1G20BLC-T | WDM-type (BiDi) SFP module with 1 1000BaseSFP |
| SFP-IGZUBLC-I | |
| | port with LC connector for 20 km transmission; TX |
| | 1550 nm, RX 1310 nm, -40 to 85°C operating |
| SFP-1G40ALC | temperature |
| SFP-1G4UALC | WDM-type (BiDi) SFP module with 1 1000BaseSFP |
| | port with LC connector for 40 km transmission; TX |
| | 1310 nm, RX 1550 nm, 0 to 60°C operating |
| | temperature |

| Module | Description |
|-----------------|---|
| SFP-1G40ALC-T | WDM-type (BiDi) SFP module with 1 1000BaseSFP |
| | port with LC connector for 40 km transmission; TX |
| | 1310 nm, RX 1550 nm, -40 to 85°C operating |
| | temperature |
| SFP-1G40BLC | WDM-type (BiDi) SFP module with 1 1000BaseSFP |
| SIT IGTODEC | port with LC connector for 40 km transmission; TX |
| | 1550 nm, RX 1310 nm, 0 to 60°C operating |
| | temperature |
| SFP-1G40BLC-T | WDM-type (BiDi) SFP module with 1 1000BaseSFP |
| SFP-IG40DLC-1 | port with LC connector for 40 km transmission; TX |
| | 1550 nm, RX 1310 nm, -40 to 85°C operating |
| | temperature |
| SFP-1GSXLC | SFP module with 1 1000BaseSX port with LC |
| SFP-IGSALC | |
| | connector for 300m/550m transmission, 0 to 60°C |
| | operating temperature |
| SFP-1GSXLC-T | SFP module with 1 1000BaseSX port with LC |
| | connector for 300m/550m transmission, -40 to |
| | 85°C operating temperature |
| SFP-1GLSXLC | SFP module with 1 1000BaseLSX port with LC |
| | connector for 1km/2km transmission, 0 to 60°C |
| | operating temperature |
| SFP-1GLSXLC-T | SFP module with 1 1000BaseLSX port with LC |
| | connector for 1km/2km transmission, -40 to 85°C |
| | operating temperature |
| SFP-1GLXLC | SFP module with 1 1000BaseLX port with LC |
| | connector for 10 km transmission, 0 to 60°C |
| | operating temperature |
| SFP-1GLXLC-T | SFP module with 1 1000BaseLX port with LC |
| | connector for 10 km transmission, -40 to 85°C |
| | operating temperature |
| SFP-1GLHLC | SFP module with 1 1000BaseLH port with LC |
| | connector for 30 km transmission, 0 to 60°C |
| | operating temperature |
| SFP-1GLHLC-T | SFP module with 1 1000BaseLH port with LC |
| | connector for 30 km transmission, -40 to 85°C |
| | operating temperature |
| SFP-1GLHXLC | SFP module with 1 1000BaseLHX port with LC |
| | connector for 40 km transmission, 0 to 60°C |
| | operating temperature |
| SFP-1GLHXLC-T | SFP module with 1 1000BaseLHX port with LC |
| | connector for 40 km transmission, -40 to 85°C |
| | operating temperature |
| SFP-1GZXLC | SFP module with 1 1000BaseZX port with LC |
| | connector for 80 km transmission, 0 to 60°C |
| | operating temperature |
| SFP-1GZXLC-T | SFP module with 1 1000BaseZX port with LC |
| - | connector for 80 km transmission, -40 to 85°C |
| | operating temperature |
| SFP-1GEZXLC | SFP module with 1 1000BaseEZX port with LC |
| | connector for 110 km transmission, 0 to 60°C |
| | operating temperature |
| SFP-1GEZXLC-120 | |
| | connector for 120 km transmission, 0 to 60°C |
| | operating temperature |
| | operating compensation |

| Module | Description |
|----------------|--|
| SFP-1GTXRJ45-T | SFP module with 1 1000BaseT port with RJ45 |
| | connector for 100 m transmission, -40 to 75°C |
| | operating temperature |
| | Note : This module is not certified for Hazardous |
| | Location. |

Restricted Access Locations

- This equipment is intended to be used in Restricted Access Locations, such as a computer room, with access limited to service personnel or users who have been instructed on how to handle the metal chassis of equipment that is very hot. The location should only be accessible with a key or through a security system.
- External metal parts of this equipment are extremely hot. Before touching the equipment, you must take special precautions to protect your hands and body from serious injury.



Special Conditions of Use

- The equipment shall only be used in an area of at least pollution degree 2, as defined in EN 60664-1.
- The equipment shall be installed in an enclosure that provides a degree of protection not less than IP 54 in accordance with EN 60079-0 and accessible only by the use of a tool.
- Transient protection device with capability of voltage clamping rating less than 119Vdc shall be provided externally of the PWR voltage supply terminal.



ATTENTION

These devices are open-type devices that are to be installed in an enclosure with tool-removable cover or door, suitable for the environment.

This equipment is suitable for use in Class I, Division 2, Groups A, B, C, and D or non-hazardous locations only.



WARNING-EXPLOSION HAZARD

Do not disconnect equipment unless power has been removed or the area is known to be non-hazardous.

Substitution of any components may impair suitability for Class I, Division 2.

Hazardous Location Usage Terms

| Usage Terms | | | | |
|--------------------|--|--|--|--|
| Models | MDS-G4012, MDS-G4012-T | | | |
| | MDS-G4020, MDS-G4020-T | | | |
| | MDS-G4028, MDS-G4028-T | | | |
| Rating | Input: 24 to 48 VDC, 3.3 A (for PWR input) and 48 | | | |
| | VDC, 8.2 A (for EPS input) | | | |
| | Relay Output: 30 VDC/1 A | | | |
| | Digital Input: 30 VDC/8 mA | | | |
| | PoE Output: 48 VDC, 15.4 W per port | | | |
| Conductors | ≥105°C | | | |
| suitable for rated | t de la constante de | | | |
| cable | | | | |
| temperature | | | | |
| Hazardous | EN IEC 60079-0:2018 | | | |
| Location | EN IEC 60079-7:2015+A1:2018 | | | |
| | EN IEC 60079-15: 2019 | | | |
| | Class I, Division 2, Groups A, B, C, and D | | | |
| Addressof | No. 1111, Heping Rd., Bade Dist., Taoyuan City | | | |
| manufacturer | 334004, Taiwan | | | |

| CID2 | | | | |
|--|------------|-----|--|--|
| LISTED I.T.E. for Use in Hazardous Locations 86CY Class I, Division 2 Groups A, B, C and D | Temp. Code | ТЗВ | | |

| ATEX | | | | |
|------|----------------------|---------------------------------|--|--|
| | Temp. Code | 165°C (T3) | | |
| | Certification Number | UL 20 ATEX 2415X | | |
| | Protection type code | Ex ec nC IIC 165°C (T3) Gc | | |
| | Warning | Do not open or disassemble the | | |
| | | device while it is in operation | | |